

- 1. ALL THRU PIPE SHALL BE FITTED WITH SCH. 40 PVC REMOVABLE CAP.
- 2. ALL PLUGS SHALL BE SECURED TO THE DROP FITTING WITH 2 FEET OF GALVANIZED CHAIN SECURED WITH TWO STEEL MACHINE SCREWS, NUTS, AND WASHERS.
- 3. DROP STACK SHALL BE SCH. 40 PVC AND STRAPPED TO MANHOLE AT PIPE JOINTS. STRAPS AND FASTENERS SHALL BE STAINLESS STEEL.
- 4. ELBOW AT BOTTOM OF THE STACK SHALL BE A 45° BEND POSITIONED IN THE DIRECTION OF THE FLOW WITH BENCH CONSTRUCTED TO CONFORM TO MANHOLE BENCH.
- 5. A RELINER OR PREDL LOW PROFILE INSIDE DROP SHALL BE USED IN LIEU OF PVC PIPING INSIDE EXISTING 4 FT. DIA. MANHOLES.
- 6. FOR EXISTING M.H.s >4 FT. DIA., A RELINER OR PREDL LOW PROFILE INSIDE DROP OR PVC PIPING AS SHOWN MAY BE USED.

